

AEL Solutions Awning Electrical Specification

Total loading

Max load for awning motor is 420 watts.

Supply required

Remote control awnings require a 3 core supply (black and brown cables coming out from the awning are both placed into the one live feed).
All feeds should terminate at an isolator box located within 1m of the end of the awning (depending which side motor has been ordered on).

Wall Heaters

Loading for these varies from 1KW to 2.1KW (dependant on model ordered)
All feeds should terminate at an isolator box located within 1m of the end of the heater. 3 core cable required.

NOTE

All awnings are earth bond tested before leaving factory.
All awnings are insulation tested before leaving factory.
All awnings are leak tested before leaving factory.

A&E Leisure Ltd
9 Cradock Road
Reading RG2 0JT
Tel 0118 9230300
Fax 0118 9230349
sales@aelolutions.com
www.aelolutions.com

